

DIVISION OF INDUSTRY SERVICES
Plumbing Product Review
P.O. Box 2658
Madison, Wisconsin 53701-2658

TTY: Contact Through Relay

Scott Walker, Governor Dave Ross, Secretary

June 24, 2015

GLACIER WATER SERVICES INC. THOMAS A. CONTI 1385 PARK CENTER DR VISTA CA 92081

Re: Description: WATER TREATMENT DEVICE - BOTTLED WATER VENDING MACHINE

Manufacturer: GLACIER WATER SERVICES INC. Product Name: GLACIER WATER (trans id 2565364)

Model Number(s): IB2D Product File No: 20150173

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of June 2020.

This approval supersedes the approval issued on July 27, 2010 under product file number 20070175.

This approval is contingent upon compliance with the following stipulation(s):

- This product has undergone sufficient testing to document the product's ability to reduce only those
 contaminants and/or substances as specified in this approval letter when the product is installed and maintained
 in strict accordance with the manufacturer's published instructions.
- Where the Department of Natural Resources (DNR) has jurisdiction, a written approval may be required prior to installation of this product in a water supply system to reduce the concentration of a contaminant that exceeds the primary drinking water standards contained in ch. NR 809, Wis. Admin. Code, the enforcement standards contained in ch. NR 140, Wis. Admin. Code, or for a water supply system that is subject to a written advisory opinion by the DNR. For more information contact the DNR Section of Private Water Systems, P.O. Box 7921, Madison, WI 53707, telephone (608) 267-9787.
- If this approved device is modified or additional assertions of function or performance are made, then this approval shall be considered null and void, unless the change is submitted to the department for review and the approval is reaffirmed.
- The system shall be provided with an in-line total dissolved solids (TDS) monitor, or other acceptable means, to warn the user when the system is not performing its functions. Acceptable alternatives to an in-line TDS monitor include:
 - 1. terminating the discharge of treated water;
 - 2. sounding an alarm which is connected to acceptable power source;
 - 3. flashing a light connected to an acceptable power source;
 - 4. providing the user with an obvious, readily interpretable, indication of the system's ability to perform (e.g. decreasing the flow rate of treated water by 50% or more for systems making mechanical filtration claims;

SBD-10564-E (N.10/97) File Ref: 15017302.DOC

Glacier Water Services Inc.

June 24, 2015 Page 2 of 2

Product File: 20150173

- 5. providing a sampling service by the manufacturer, either directly or through an authorized dealer, a minimum of once every six months;
- 6. providing a sampling kit for analysis of TDS or other appropriate contaminants; or
- 7. providing a TDS monitor to measure the product water quality.

Whichever means of performance verification is selected it shall be clearly described in the owner's manual for this device, and approved for use along with the device.

- The Kuri Tec Clearbraid K3150 water supply tubing is for cold water use only.
- The sump discharge pump must be installed so that the total developed dynamic head pressure does not exceed 20 feet.
- The Kuri Tec K3150 Clearbraid drain line and/or water supply tubing installed in the horizontal direction must have continuous support; drain line or water supply tubing installed in the vertical direction must be supported every 4 feet.

If the Kuri Tec K3150 Clearbraid tubing is installed in an area in which it prone to being crushed or cut, then the tubing must be sleeved with a rigid material.

Based on testing data submitted to and reviewed by the department, this approval recognizes that this plumbing
product will reduce the concentration of contaminants as specified on pages 1 through 2 of this letter.

AESTHETIC INORGANIC CONTAMINANT REDUCTION CAPABILITIES PRODUCT FILE NUMBER 20150173 TABLE 1 OF 1

Production Rate: 772 gallons per day (gpd) [2,922 liters per day (lpd)]

Tested Contaminant	Tested Influent Concentration (mg/l) ¹
Total Dissolved Solids (TDS)	750 ± 40

Other Conditions: the contaminant reduction capabilities displayed for Table 1 of 1 were generated by testing conducted in accordance with ANSI/NSF Standard 58. To qualify, the device shall reduce the influent challenge concentrations by $\geq 75\%$.

1 = milligrams per liter (mg/l) are equivalent to parts per million (ppm).

± = plus or minus

 \geq = greater than or equal to

This device was tested under controlled laboratory, or field, conditions. The actual performance of this device for a specific end use installation will vary from the tested conditions based on local factors such as water pressure, water temperature and water chemistry.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen W. Schlueter
Environmental Engineer - Plumbing Product Reviewer
Depart of Safety and Professional Services
Division of Industry Services
Bureau of Technical Services
(608) 267-1401 Phone
(608) 267-9723 Fax
glen.schlueter@wi.gov E-mail